



FIRE SAFETY REQUIREMENTS EVENTS & FESTIVALS IN SURREY

Follow these requirements to prevent delays or disruptions and to ensure a safe and fun event for everyone.

OUTDOOR EVENTS

FIRE EXTINGUISHERS

- ❑ Must have a minimum rating of 2A-10BC. *Not sure what this means? Learn about ratings by searching Fire Extinguishers at www.ccohs.ca.*

LOCATION

- ❑ Must be located within the area occupied by each tent.
- ❑ Must be within a 75 ft (23 m) walking distance.
- ❑ Must be mounted in a visible location – not on the floor or behind another object.

SERVICING AND CONDITION


- ❑ Must have a current service tag.
- ❑ Maintenance report must be provided if requested to identify any deficiencies.
- ❑ Must be full and functioning with no leaks, damage, corrosion or clogged nozzles.

K-CLASS EXTINGUISHERS

(Required for cooking with woks or deep fryers)

- ❑ Must have a current service tag.
- ❑ Must be within 75 ft (23 m) of all kitchen areas.

WILL FOOD BE COOKED OR HEATED AT YOUR EVENT?



- ❑ Appropriate fire extinguishers must be located at each cooking area with no more than 30 ft (9 m) between extinguishers.
- ❑ If cooking in a wok or deep frying, see K-Class extinguisher information at left.

TENTS USED FOR COOKING/HEATING FOOD:

- ❑ Must have the appropriate fire extinguishers.
- ❑ Must be made of material with a flame-spread rating equivalent to CAN/ULC S-109. Look for this on the package or tag.



MORE ►

Surrey Fire Services Fire Prevention
604-543-6780 or fireprevention@surrey.ca
www.surrey.ca/fireservice

Event hosting info: www.surrey.ca/eventhosting

