



PURCHASING SECTION
13450 – 104th Avenue, Surrey, B.C. V3T 1V8
Tel: 604-590-7274 Fax: 604-599-0956
E-mail: purchasing@surrey.ca

ADDENDUM NO. 1

REQUEST FOR PROPOSALS (RFP) NO.: 1220-030-2016-001
TITLE: WATER CROSS CONNECTION CONTROL SURVEY
ADDENDUM ISSUE DATE: JUNE 10, 2016
CLOSING DATE: 3:00 P.M. ON JUNE 20, 2016

INFORMATION FOR PROPONENTS

This Addendum is issued to provide additional information and clarifications to the RFP for the above named project, to the extent referenced and shall become a part thereof. No consideration will be allowed for extras due to the Proponent or any sub-Proponent not being familiar with this addendum. This Addendum No. 1 contains one (1) page in total.

Q.1. Are there any areas of confined space which need to be accessed in order to conduct the survey?

A.1. Consultants do not need to enter confined spaces. They may ask the owner's permission to open the cover of the chamber or crawl space and observe what's inside. If the Consultant is unable to see the serial number of the backflow preventer, they may just record the type and estimate the size of the backflow preventer.

END OF ADDENDUM

All Addenda will become part of the RFQ Documents.
