



PURCHASING SECTION
13450 – 104 Avenue, Surrey, B.C. V3T 1V8
Tel: 604-590-7274 Fax: 604-599-0956
E-mail: purchasing@surrey.ca

ADDENDUM NO. 3

REQUEST FOR QUOTATIONS (RFQ) NO.: 1220-040-2016-032

TITLE: MINOR DRAINAGE PROJECTS

ADDENDUM ISSUE DATE: AUGUST 4, 2016

CLOSING DATE: PREFER TO RECEIVE QUOTATIONS ON OR
BEFORE AUGUST 10, 2016.

INFORMATION FOR CONTRACTORS

This Addendum is issued to provide additional information to the RFQ for the above named project, to the extent referenced and shall become a part thereof. No consideration will be allowed for extras due to the contractor not being familiar with this addendum. This Addendum No. 3 contains one (1) page in total.

Q1. C-2.00 & C-3.00

Drawing SSD-D.11 Headwall details does not address the tie back requirement of the 10 DIA.Galv'd. S.W.R. for the culvert lengths. Please clarify.

A1. For C-2.00 & C-3.00 please install deadmen tie back piles at approximately 3 metres in the crossing. Cabling remains the same.

Q2. Looking at the Timber Headwall detail drawing SSD-D.11 there is rip rap shown around the headwall and culvert pipe, but the size is not specified. Can you confirm if rip rap is expected on this project, and what size rip rap should be used (i.e. class 25kg rip rap)?

A2. Rip rap is not required.

END OF ADDENDUM

All Addenda will become part of the RFQ Documents.
