



PURCHASING SECTION
13450 – 104 Avenue, Surrey BC V3T 1V8
Tel: 604-590-7274
E-mail: purchasing@surrey.ca
ADDENDUM #1

REQUEST FOR QUOTATIONS (RFQ) NO.:	1220-040-2016-071
TITLE:	FUEL ISLAND DISPENSERS REPLACEMENT FOR SURREY MAIN OPERATIONS CENTRE
ADDENDUM ISSUE DATE:	August 10, 2016
CLOSING DATE:	prefer to receive Quotations on or before: August 12, 2016

INFORMATION FOR CONTRACTORS

This Addendum is issued to provide additional information to the RFQ for the above named project, to the extent referenced and shall become a part thereof. No consideration will be allowed for extras due to the Contractor not being familiar with this Addendum. This Addendum No. 1 contains one (1) page in total.

Q1: The RFQ talks about the diesel dispensers having internal filters and the gasoline dispensers having external filters. Typically this is reversed, can you please confirm.

A1: Dispensers should have filters (either external or internal) that are easily accessible for maintenance.

END OF ADDENDUM #1

All Addenda will become part of the RFQ Documents.
