



PURCHASING SECTION
13450 – 104 Avenue, Surrey BC V3T 1V8
Tel: 604-590-7274
E-mail: purchasing@surrey.ca

ADDENDUM #2

REQUEST FOR QUOTATIONS (RFQ) NO.: 1220-040-2017-024
TITLE: ROOF REPLACEMENT AT FLEETWOOD LIBRARY
ADDENDUM ISSUE DATE: January 25, 2017
CLOSING DATE: prefer to receive Quotations on or before:
January 31, 2017.

INFORMATION FOR CONTRACTORS

This Addendum is issued to provide additional information to the RFQ for the above named project, to the extent referenced and shall become a part thereof. No consideration will be allowed for extras due to the Contractor not being familiar with this Addendum. This Addendum No. 2 contains one (1) page in total.

QUESTIONS AND ANSWERS:

Q1: As per the specs, Section 07 52 10 2.6 Tapered Insulation:

- .2 Tapered Drainage Sumps: Closed-cell polyisocyanurate foam rigid insulation boards to ASTM C1289 Type II, Class 1, 2, or 3, Grade 2, manufactured with HCFC-free blowing agent (Pentane) bonded during manufacturing process to inorganic coated glass facers on top and bottom surfaces:
 - .1 Size to be 2.4m x 2.4m (8' x 8') and tapered from 38mm (1.5") at edge down 4%. Reduce width of tapered sheet by 300mm (12") to produce a 900mm (3') wide strip from 1.5" to a 610mm x 610mm (2' x 2') central flat area 19mm (0.5") in thickness.

The above 8x8 sump can only be achieved with 2% material or reduce the sump size to 4x4 and use a one-piece 4% Drain Set. Examples:

- X panel, 4x4, 2%, min 0.5"-1.5"
- Q panel, 4x4, 4% min 0.5"-2.5"
- Drain Set, 4x4, 4%, min 0.5"-1.5"

A1: Reduce flat roof drain sumps to 4' x 4' dimension and install a one piece 4% drain set.

END OF ADDENDUM #2

All Addenda will become part of the RFQ Documents.
