



PURCHASING SECTION  
13450 – 104 Avenue, Surrey, BC V3T 1V8  
Tel: 604-590-7274 Fax: 604-599-0956  
E-mail: [purchasing@surrey.ca](mailto:purchasing@surrey.ca)

**ADDENDUM No. 4**

---

REQUEST FOR QUOTATIONS (RFQ) NO.: 1220-040-2018-043  
TITLE: WATER METER MAINTENANCE SERVICES  
ADDENDUM ISSUE DATE: JUNE 26, 2018  
**\*\*\* REVISED DATE: PREFER TO RECEIVE QUOTATIONS ON OR BEFORE  
JUNE 29, 2018**

---

**INFORMATION FOR CONTRACTORS**

This Addendum is issued to provide answers to questions raised by potential Contractor for the above named project, to the extent referenced and shall become a part thereof. No consideration will be allowed for extras due to the Contractor not being familiar with this addendum. This Addendum No. 4 contains two (2) pages in total.

**1. QUESTIONS & ANSWERS**

**REFER TO SCHEDULE A, SECTION 9 - MAINTENANCE SERVICE ITEMS**

Q1. Item (j) Replace Register- Sensus SR11 Meter: What is the register size for the quantity of 50?

**A1. Answer: Remove that quantity from that line item.**

Q3. Item (m) Replacement of Water Meter System: Confirm the depth is 0 – 1.5 ?

**A3. Answer: (m) should read 0 m – 1.5 m (depth)**

Q4. Item (g) Meter Testing – Field Testing: Do the meters have a bypass and test port for field testing?

**A4. Answer: not all locations are equipped with test ports or by-passes.**

Q5. Item (j) Replace Register – Sensus SR11 (digital): The manufacturer no longer produces SR11 registers for the 38MM and 50MM sizes. Should those two sizes be omitted from the quote?

**A3. Answer: Yes. Remove 38mm and 50mm from this quote.**

**2. REFER TO SCHEDULE A – SCOPE OF SERVICES**

**Delete:**

**2.1 Water Meter Maintenance Program**

The City anticipates that on an annual basis approximately 1500-2000 positive displacement meters will experience read difficulties and require maintenance to address one or more of maintenance items as listed in Schedule B-2.

Water meters requiring maintenance under program work will be provided to the Contractor in monthly maintenance service lists and work orders generated by the City's work management system (Cityworks).

**Replace with:**

**2.2 Water Meter Maintenance Program**

The City anticipates that on an annual basis approximately 1500-2000 positive displacement meters will experience read difficulties and require maintenance to address one or more of maintenance items as listed in Schedule B-2.

Water meters requiring maintenance under program work will be provided to the Contractor in monthly maintenance service lists and work orders generated by the City's work management system (Cityworks).

Monthly lists provided by the city must be completed 2 months after receiving the list of locations and updates on the progress must be provided weekly.

**END OF ADDENDUM**

---

---

All Addenda will become part of the RFQ Documents.

---

---