



PURCHASING SECTION
 13450 – 104 Avenue, Surrey, BC V3T 1V8
 Tel: 604-590-7274
 E-mail: purchasing@surrey.ca

ADDENDUM No. 2

**REQUEST FOR EXPRESSIONS OF
 INTEREST AND STATEMENTS OF
 QUALIFICATIONS.:**

1220-050-2017-027

TITLE:

**PRE-QUALIFICATION FOR CIVIL CONTRACTORS
 City of Surrey Watermain Rehabilitation by Cured
 In Place Pipe (CIPP) Lining**

ADDENDUM ISSUE DATE:

NOVEMBER 23, 2017

REVISED CLOSING DATE:

**PREFER TO RECEIVE SUBMISSIONS ON OR
 BEFORE NOVEMBER 27, 2017.**

INFORMATION FOR RESPONDENTS

Contractors are advised that Addendum No. 2 to RFEOI/SOQ 1220-050-2017-027 is hereby issued by the City. This addendum shall form part of the Contract Documents and is to be read, interpreted and coordinated with all other parts. The following information is provided to answer questions raised by Contractors for the above named project, to the extent referenced and shall become a part thereof. No consideration will be allowed for extras due to the Contractor or any sub-contractor not being familiar with this addendum. This Addendum No. 2 contains two (2) pages in total.

QUESTIONS AND ANSWERS:

Q1. What is the ex pipe material.

A1.

Project ID	Project Number	Description	Location	Material
11581	1210-3310-00	1000m of 300mm diameter	96 Ave: 120 St to 125 St	CI
13840	1215-3610-00	2300m of 300mm diameter	116 Ave: 112a Ave to 132 St	CI/DI
9934	1215-2620-00	1000m of 300mm diameter	96 Ave: 131 St to 136 St	CI
13884	1215-3620-00	830m of 300mm diameter	96 Ave: 156 St to 160 St	AC

Q2. How many and the size of services.

A2. The exact number of services along the project area is not confirmed at this time. The residential areas are primarily 19mm and commercial/industrial are typically 100mm and above.

Q3. Would the City also allow experience not only from watermain installation but also all pressure pipe CIPP installation?

A3. Experience provided from the respondent and/or the sub-contractor for liner installation in non-potable pressurized pipe can be submitted if required to fulfill the experience requirement; however, the majority of lining experience presented must be through the installation of CIPP Watermain Lining. The City will use discretion when determining if the watermain lining experience presented is satisfactory for pre-qualification.

Q4. In Section 4, liner requirements, it is asked that the supplied liner design be stamped by an experience PE licenced in BC. We were unsuccessful in finding a PE licenced in BC with sufficient CIPP liner design experience to stamp our designs. We have the design stamped by an Ontario engineer with extensive liner design experience that is also in the process of getting a British Columbia license. Would that cause a problem for this RFEOI.

A4. The design can be stamped by an experienced registered Engineer in Canada for the RFQ stage. Please note that for the tender stage designs must be stamped by an experienced professional engineer licensed to practice in the Province of British Columbia.

- END OF ADDENDUM -

All Addenda will become part of the RFEOI/SOQ Documents.
