



PROCUREMENT SERVICES
CITY OF SURREY, SURREY CITY HALL
13450 – 104 Avenue, Surrey, B.C., V3T 1V8

Tel: 604-590-7274

E-mail: purchasing@surrey.ca

ADDENDUM #2

REQUEST FOR QUOTATIONS (RFQ) No.:	1220-040-2019-105
TITLE:	CHILLER PREVENTATIVE MAINTENANCE SERVICES
ADDENDUM ISSUE DATE:	MARCH 6, 2020
REVISED DATE:	prefer to receive Quotations on or before March, 11, 2020.

INFORMATION FOR CONTRACTORS

This Addendum is issued to provide additional information to the RFQ for the above named project, to the extent referenced and shall become a part thereof. No consideration will be allowed for extras due to the Contractor not being familiar with this Addendum. This Addendum No. 2 contains one (1) page in total.

QUESTIONS AND ANSWERS:

- Q1.** In Schedule A-1 item 1.6 Could the city define the “common” parts required? If not, can the contractor provide a list to form part of the agreement?
- A1.** **Contractor should provide the list of common parts they will carry.**
- Q2.** In Schedule A item 5.1 Third Party Inspections: Can the city provide examples or quantify the number of inspections required to meet this requirement?
- A2.** **This will be case by case basis and depending on the magnitude of the repair.**
- Q3.** An updated equipment list (Page 38) and filter list were discussed at the Information Meeting on February 25. This was to be issued in an Addendum. The information does not appear in the attachment.
- A3.** **Total of 16 filters for Aeon units in Surrey Art Center and sizes are, 16x20x2 Merv 10.**

- END OF ADDENDUM -

All Addenda will become part of the RFQ Documents.
