



PROCUREMENT SERVICES

CITY OF SURREY, SURREY CITY HALL
13450 – 104 Avenue, Surrey, B.C., V3T 1V8
Tel: 604-590-7274
E-mail: purchasing@surrey.ca

ADDENDUM No. 3

REQUEST FOR QUOTATIONS (RFQ) No.: 1220-040-2020-013
TITLE: DON CHRISTIAN – CHILDCARE MODULAR BUILDING
ADDENDUM ISSUE DATE: JULY 6, 2020
REVISED DATE: PREFER TO RECEIVE QUOTATIONS ON OR BEFORE JULY 9, 2020.

INFORMATION FOR CONTRACTORS

Contractors are advised that Addendum No. 3 to 1220-040-2020-013 is hereby issued by the City. This addendum shall form part of the contract documents and is to be read, interpreted and coordinated with all other parts. The following information is provided to answer questions raised by Contractors for the above-named project, to the extent referenced and shall become a part thereof. No consideration will be allowed for extras due to the Contractors or any sub-contractor not being familiar with this addendum. This Addendum No. 3 contains one (1) page.

QUESTIONS AND ANSWERS:

- Q1. Regarding Addendum No. 1 for RFQ 1220-040-2020-013: in Q5 please confirm if the insulation to be included to floor, walls and roof is batt insulation with poly or spray foam?
- A1. Refer to A1 in Addendum No. 2: Please use Rockwool since it is vapor permeable.
- Q2. In List of Separate Pricing in the RFQ, should we include items SP-8 and SP-9?
- A2. No, delete SP-8 and SP-9 from List of Separate Pricing in the RFQ.
- Q3. Please confirm interior doors finish since fiberglass usually is just for exterior applications. Can we propose solid core wooden doors instead?
- A3. Revise the interior door type from fiberglass to solid wood.

All Addenda will become part of the Contract Documents.

- END OF ADDENDUM -