



**PROCUREMENT SERVICES**  
City of Surrey, Surrey City Hall  
13450 – 104 Avenue, Surrey, BC V3T 1V8  
Tel: 604-590-7274  
E-mail: [purchasing@surrey.ca](mailto:purchasing@surrey.ca)

**ADDENDUM No. 1**

---

**REQUEST FOR QUOTATIONS (RFQ) No.:** 1220-040-2020-020

**TITLE:** PAVEMENT MARKINGS

**ADDENDUM ISSUE DATE:** February 4, 2020

**CLOSING DATE:** Prefer to receive Quotations on or before:  
February 14, 2020

---

**INFORMATION FOR CONTRACTORS**

This Addendum is issued to provide additional information to the RFQ for the above named project, to the extent referenced and shall become a part thereof. No consideration will be allowed for extras due to the Contractor not being familiar with this addendum. This Addendum No. 1 contains two (2) pages in total.

**QUESTIONS & ANSWERS**

Q1: Please provide historical data for the purpose of time schedule estimation and accurate bid for:

- a) Item 1 Spray thermoplastic white, what's the mix approximately of 1:1, 3:6:3, and solid makes up the 800,000m?  
Our inventory quantifies the total linear metres which totals the 800,00 metres. The mix would be determined site specifically.
- b) Item 2 Screed thermoplastic yellow, whats the mix approximately of 1:1, 3:6:3, and solid makes up the 200,000m?  
Our inventory quantifies the total linear metres which totals the 200,00 metres. The mix would be determined site specifically.
- c) Item 8 MMA 10cm wide, what's the mix approximately of 1:1, 3:6:3, and solid makes up the 150,000m and advise to how many locations you think this will be required?  
Our inventory quantifies the total linear metres which totals the 150,00 metres. The mix would be determined site specifically. Locations to be determined.

- d) Item 9 Inlaid 10cm thermoplastic line, please provide the mix approximately of 1:1, 3:6:3, and solid makes up the 25,000m and advise to how many locations you think this will be required?  
**Our inventory quantifies the total linear metres. The mix would be determined site specifically. Locations to be determined.**
- e) Item 12 please provide historical data on how much and what type of eradication work is generally required?  
**The quantities vary every year.**
- f) How many call outs does the city require generally and please provide some reasons why callouts are made?  
**Varies every year.**

Q2: Please describe the typical amount of new construction works you require a contractor to install on a given year and confirm what is required of a marking contractor on these?

**A2: Varies every year.**

Q3: Material thickness - RFQ document states 80mm (3.14 inches) thick for spray thermoplastic, 60mm (2.36 inches) thick for mma, 125mm (4.92 inches) thick for extrude, and 3mm (.118 inches) for colored screed mma. All of the thicknesses seem incorrect with the exception of the screed mma, please confirm the required thicknesses for each item?

**A3: Please correct to the below information:**

**Spray thermoplastic road markings shall not be less than 80 mil in thickness.**

**Spray MMA road markings shall not be less than 60 mil in thickness**

**Mechanical extrusion thermoplastics markings including stop bars, crosswalks, arrows and longitudinal lines shall not be lesser than 125 mil in thickness.**

**Application either through spray or mechanical extrusion shall be uniform and consistent throughout the total length of the line or symbol.**

**Coloured MMA screed road markings shall not be lesser than 3 mm in thickness.**

---

---

**All Addenda will become part of the Contract Documents.**

---

---

**- END OF ADDENDUM -**