



## PROCUREMENT SERVICES

CITY OF SURREY, SURREY CITY HALL  
13450 – 104 Avenue, Surrey, B.C., V3T 1V8  
Tel: 604-590-7274  
E-mail: [purchasing@surrey.ca](mailto:purchasing@surrey.ca)

### ADDENDUM No. 4

---

REQUEST FOR QUOTATIONS (RFQ) No.: 1220-040-2020-021  
TITLE: DON CHRISTIAN – SITE WORK FOR CHILDCARE  
MODULAR BUILDING  
ADDENDUM ISSUE DATE: JULY 7, 2020  
**REVISED DATE:** PREFER TO RECEIVE QUOTATIONS ON OR  
BEFORE JULY 9, 2020.

---

### INFORMATION FOR CONTRACTORS

Contractors are advised that Addendum No. 4 to 1220-040-2020-021 is hereby issued by the City. This addendum shall form part of the contract documents and is to be read, interpreted and coordinated with all other parts. The following information is provided to answer questions raised by Contractors for the above-named project, to the extent referenced and shall become a part thereof. No consideration will be allowed for extras due to the Contractors or any sub-contractor not being familiar with this addendum. This Addendum No. 4 contains one (1) page.

#### CLARIFICATION:

1. **Add in Drawing S200 – Foundation Plan Sections & Details; Allow for two openings in centre wood pony wall. Use 3-38x184 header complete with a built up post of 2 cripples and one king stud to match the wall assembly. Exact locations to be confirmed after review of modular shop drawings.**

#### QUESTION AND ANSWER:

Q1. We received a question from Electrical trade asking if Consultant would accept DB2 ducting for Underground Conduit for power and communication. Drawing listed rigid PVC.

**A1. DB2 conduit is acceptable.**

---

All Addenda will become part of the Contract Documents.

---

- END OF ADDENDUM -