



PROCUREMENT SERVICES SECTION
CITY OF SURREY, SURREY CITY HALL
13450 – 104 Avenue, Surrey, B.C., V3T 1V8
Tel: 604-590-7274
E-mail: purchasing@surrey.ca

ADDENDUM No. 2

REQUEST FOR QUOTATION NO.:	1220-040-2020-022
TITLE:	SUPPLY, DELIVERY, INSTALLATION AND COMMISSIONING OF AV EQUIPMENT, CLAYTON COMMUNITY CENTRE
ADDENDUM ISSUE DATE:	February 13, 2020
DATE:	PREFER TO RECEIVE QUOTATIONS ON OR BEFORE February 18, 2020.

INFORMATION FOR CONTRACTORS

This Addendum is issued to provide additional information and clarifications to the RFQ for the above named project, to the extent referenced and shall become a part thereof. No consideration will be allowed for extras due to the Contractor not being familiar with this addendum. This Addendum No. 2 contains two (2) page in total.

QUESTIONS AND ANSWERS:

Q1.

Our team would like clarification on what is required in regard to Section 2.9. As the cables are provided on the equipment list for the specific areas, our understanding is that the cable plant, patch cables and interconnects will be provided and installed by the GC. If we are required to provide such materials and installation, please provide your expectations.

A1.

All cable plant is provided by the GC. Proponents shall only provide interconnect cables for equipment that require a connection to the GC supplied equipment. For example: Digital Media Players for digital signage displays, provide the network patch cord and HDMI interconnect cable. Another example: Ceiling-mount projectors: Provide interconnect cables HDMI and RS232 or Network Patch Cord, as required.

Q2.

Regarding the Dalite screens, the supplier has advised me that the screens come standard with 12" black drop.

The RFQ spec. indicates variables of 6", 12", and 24" black drop. Is that in addition to the 12" black drop already incorporated?

A2.

Yes, the requested extra black drops are in addition to the standard 12" black drop that is included with the Dalite Tensioned Cosmo Electrol screens.

Q3.

For section 2.1.4 (equipment for Visual Arts 114) shows a projection screen, but no projector. Please confirm if this is an oversight and advise if you need a projector as well for this room.

A3.

No projectors are required in Visual Arts 114.

CLARIFICATIONS FOR SUBSTITUTIONS:

Q4.

We would like to submit for consideration the following substitutions for the Projector portion of this BID. We believe these meet and exceed the technical specifications and offer a consistent manufacture with an excellent warranty advance replacement for their product.

A4.

Please refer to Section 14. PRODUCT/ SYSTEM OPTIONS AND APPROVALS of the RFQ document.

QTY	Spec Mfg	NEC Mfg. P/N	Size	Description
5	Panasonic PT-EZ590	NP-P525UL		NEC DISPLAY SOLUTIONS: WUXGA LCD, Laser Light Source, 20,000 hours light source life, 5200 Lumen Entry Installation Projector - Lens Shift, HDBaseT, Dual HDMI, VGA, MultiPresenter, USB Viewer Capability, Closed Captioning, 21.3 lbs., 5 Year Warranty (Suggested Replacement Model)
1	Christie Digital DWU1075-GS	NP-PX1004UL-BK		NEC DISPLAY SOLUTIONS: 10,000-lumen Professional Installation Laser Projector, Native: WUXGA 1920 x 1200, Maximum:4K 4096 x 2160, Screen Size (diagonal):40 to 300 in, Projection Distance:1.5 to 179.8 ft.
1	Christie Digital 140-102104-01	NP18ZL		NEC DISPLAY SOLUTIONS: 1.73 - 2.27:1 Standard Throw Zoom Lens (lens shift) w/Lens Memory for the NP-PX700W/750U/800X projectors
1	Panasonic PT-EZ770Z	NP-PA703UL		NEC DISPLAY SOLUTIONS: LAN- P-PA703UL - LCD Projector - 7000 - 1920 x 1200 - 25000000:1 with light adjust - 16:10 - Dimension 22.8 x 19.4 x 8.2 in
1	Panasonic ET-ELW22	NP40ZL		NEC DISPLAY SOLUTIONS: 1.1:1 ZOOM LENS THE NP-PA653U/PA803U SHORT THROW LENS STL

Proposed alternate NEC model NP-P525UL is an acceptable alternative to the specified Panasonic PT-EZ590 projector.

Proposed alternate NEC model NP-PX1004UL-BK is not acceptable. Fan noise is twice as loud as specified (42dB vs 35dB = 7-dB louder).

Proposed alternate NEC model NP18ZL is not acceptable because the NEC NP-PX1004UL-BK is not an acceptable alternative.

Proposed alternate NEC model NP-PA703UL is not acceptable. Fan noise is more than twice as loud as specified (45-dB vs 35dB = 10-dB louder)

Proposed alternate NEC model NP40ZL lens is not acceptable because the NEC NP-PA703UL is not an acceptable alternative.

Q5.

Given the statutory holiday on Monday Feb 17th, please advise if an extension is possible for this RFQ.

A5.

No extension for this RFQ.

All Addenda will become part of the Contract Documents.
