



PROCUREMENT SERVICES SECTION
City of Surrey, Surrey City Hall
13450 – 104 Avenue
Surrey, B.C., V3T 1V8
Tel: 604-590-7274
E-mail: purchasing@surrey.ca

ADDENDUM NO. 1

REQUEST FOR PROPOSALS (RFP) No.: 1220-030-2020-025
TITLE: PRV Electrical/Instrumentation Need Analysis
ADDENDUM ISSUE DATE: SEPTEMBER 23, 2020
CLOSING DATE AND TIME: ON OR BEFORE THE FOLLOWING DATE AND TIME
(THE "CLOSING TIME"):
TIME: 3:00 P.M. (LOCAL TIME)
DATE: OCTOBER 5, 2020

INFORMATION FOR PROPONENTS

Proponents are advised that Addendum No. 1 to RFP 1220-030-2020-025 is hereby issued by the City. This addendum shall form part of the contract documents and is to be read, interpreted and coordinated with all other parts. The following information is provided to answer questions raised by Proponents for the above-named project, to the extent referenced and shall become a part thereof. No consideration will be allowed for extras due to the Proponent not being familiar with this addendum. This Addendum No. 1 contains two (2) pages in total.

1. QUESTIONS/ANSWERS

Q1. How many PRV stations does the City of Surrey operate now?

A1. Approximately 200.

Q2. Does the City of Surrey expect the proponent to visit some or all of the PRV sites to confirm equipment and layout?

A2. Not expected to review existing chambers. Only high level cost analysis.

Q3. How many of the PRV stations are considered to be mostly above ground and how many are classified as "Confined Space"?

A3. All confined space, exploring use of above ground.

Q4. Please confirm SCADA software as VTScada and RTU equipment as Motorola Moscad or Motorola ACE.

A4. Motarola ACE 1000, VTScada.

END OF ADDENDUM

All Addenda will become part of the RFP Documents.
