



PROCUREMENT SERVICES

CITY OF SURREY, SURREY CITY HALL
13450 – 104 Avenue, Surrey, B.C., V3T 1V8
Tel: 604-590-7274
E-mail: purchasing@surrey.ca

ADDENDUM No. 1

REQUEST FOR QUOTATIONS (RFQ) No.: 1220-040-2021-068

TITLE: Sanitary Sewer Video Inspection

ADDENDUM ISSUE DATE: October 7, 2021

CLOSING DATE AND TIME: Prefer to receive Quotations on or before October 13th, 2021.

INFORMATION FOR CONTRACTORS

Contractors are advised that Addendum No. 1 to 1220-040-2021-068 is hereby issued by the City. This addendum shall form part of the contract documents and is to be read, interpreted and coordinated with all other parts. The following information is provided to answer questions raised by Contractors for the above-named project, to the extent referenced and shall become a part thereof. No consideration will be allowed for extras due to the Contractors or any sub-contractor not being familiar with this addendum. This Addendum No. 1 contains two (2) pages.

QUESTIONS AND ANSWERS:

- Q1.** Where do we find the information or set up procedures for the ESRI product?
- A1.** The contractor's PACP inspection program must be ArcGIS compatible. Meaning that the software is an ESRI partner. The vendor of the inspection program would be the one providing support for the upload of the data. We would be only providing the ESRI license.
- Q2.** Do you have a sample of the Smoke Test Report like all the other reports as per Surrey requirements?
- A2.** Sample Smoke Testing Reports may be viewed and/or obtained at the Managed File Transfer Service (MFT) link noted below. Printing will be the sole responsibility of the Contractor.

In the URL, or address field at the top, enter the following address: <https://mft.surrey.ca/> and hit "enter".

Enter "surreybid" as the Username, "Welcome" as the password and then click "Login"

<https://mft.surrey.ca/>
Login ID: surreybid
Password: Welcome
Folder: 1220-040-2021-068

Q3. Are the manhole inspections overlapped with video inspection?

A3. Yes, the manholes to be inspected are the manholes that are up and downstream of the mains being inspected.

All Addenda will become part of the Contract Documents.

- END OF ADDENDUM -