



PROCUREMENT SERVICES

CITY OF SURREY, SURREY CITY HALL
13450 – 104 Avenue, Surrey, B.C., V3T 1V8
Tel: 604-590-7274
E-mail: purchasing@surrey.ca

ADDENDUM No. 3

INVITATION TO TENDER No.: 1220-020-2022-001

TITLE: THREE DISTRICT ENERGY ETS INSTALLATIONS
(2022-2023)

ADDENDUM ISSUE DATE: APRIL 5, 2022

**REVISED DATE: ON OR BEFORE THE FOLLOWING DATE AND
TIME (THE "CLOSING TIME"):**

TIME: 11:00 A.M. (LOCAL TIME)

DATE: APRIL 8, 2022

INFORMATION FOR TENDERERS

Tenderers are advised that Addendum No. 3 to 1220-020-2022-001 is hereby issued by the City. This addendum shall form part of the contract documents and is to be read, interpreted, and coordinated with all other parts. The following information is provided to answer questions raised by Tenderers for the above-named project, to the extent referenced and shall become a part thereof. No consideration will be allowed for extras due to the Tenderers or any sub-contractor not being familiar with this addendum. This Addendum No. 3 contains two (2) pages.

QUESTIONS AND ANSWERS:

Q1. Do the \$20,000 Supports Cash Allowances include labour to install or is the allowance for the material only?

A1. Supports cash allowance is for material only. It is expected that the supports would be installed as piping progresses and the labour would be included in the piping line item.

Q2. Please provide the type of heat exchanger because it is not specified in the drawings.

- A2. Heat exchanger types are as specified in KWL Standard Specifications Section 11500 and in Exceptions to KWL Standard Specifications in the Summary of Work (Section 01110). To clarify, space heating heat exchangers shall be Type HX01 (Single Wall Brazed Heat Exchanger) or Type HX02 (Plate and Frame Heat Exchanger), and domestic hot water heat exchanger shall be Type HX03 (Double Wall Plate and Frame Heat Exchanger). Double Wall Brazed Heat Exchangers are not accepted. Additionally, the heat exchangers must allow for some nozzle loading due to thermal expansion.**

All Addenda will become part of the Contract Documents.

- END OF ADDENDUM -