



PROCUREMENT SERVICES

CITY OF SURREY, SURREY CITY HALL
13450 – 104 Avenue, Surrey, B.C., V3T 1V8
Tel: 604-590-7274
E-mail: purchasing@surrey.ca

ADDENDUM No. 3

REQUEST FOR QUOTATIONS No.:	1220-040-2022-018
TITLE:	Storm Sewer Rapid Scan Inspection Program
ADDENDUM ISSUE DATE:	March 11th, 2022
CLOSING DATE	PREFER TO RECEIVE SUBMISSION ON OR BEFORE MARCH 16th, 2022.

INFORMATION FOR CONTRACTORS

Contractors are advised that Addendum No. 3 to 1220-040-2022-018 is hereby issued by the City. This addendum shall form part of the contract documents and is to be read, interpreted and coordinated with all other parts. The following information is provided to answer questions raised by Contractors for the above-named project, to the extent referenced and shall become a part thereof. No consideration will be allowed for extras due to the Contractors or any sub-contractor not being familiar with this addendum. This Addendum No. 3 contains one (1) page.

QUESTIONS AND ANSWERS:

Q1. For each Term there is item 1.0 video inspect storm mainlines and prepare reports and item 2.0 manhole video inspections. Are the manholes in item 2 connected to the pipes in item 1? In other words, are we inspecting manholes in one location without the connecting pipes and then moving to inspect pipes without inspecting the manhole they are connected to or are we inspecting manholes and connecting pipes in the zones for each term?

A1. **The manholes to be inspected are attached to the mains that are also being inspected, for each term. It would not make much sense to separate them.**

All Addenda will become part of the Contract Documents.

- END OF ADDENDUM -