



PROCUREMENT SERVICES

CITY OF SURREY, SURREY CITY HALL
13450 – 104 Avenue, Surrey, B.C., V3T 1V8
Tel: 604-590-7274
E-mail: purchasing@surrey.ca

ADDENDUM No. 3

REQUEST FOR QUOTATIONS No.: 1220-040-2022-048

TITLE: HVAC Unit Replacement, South Surrey Rec Centre

ADDENDUM ISSUE DATE: May 30, 2022

CLOSING DATE: PREFER TO RECEIVE SUBMISSION ON OR BEFORE JUNE 2, 2022

INFORMATION FOR CONTRACTORS

Contractors are advised that Addendum No. 3 to 1220-040-2022-048 is hereby issued by the City. This addendum shall form part of the contract documents and is to be read, interpreted, and coordinated with all other parts. The following information is provided to answer questions raised by Contractors for the above-named project, to the extent referenced and shall become a part thereof. No consideration will be allowed for extras due to the Contractors or any sub-contractor not being familiar with this addendum. This Addendum No.3 contains one (1) page.

QUESTIONS AND ANSWERS:

Q1: Is there a preferred lifting location for the project or any special circumstances we need to be aware of? Do the crane lifts need to be conducted after hours/weekends or is regular hours permitted?

A1: Hours between 6:00am - 4:00pm for craning/lifting. Preferred lifting location is the lower parking lot.

- END OF ADDENDUM -