



PROCUREMENT SERVICES

CITY OF SURREY, SURREY CITY HALL
13450 – 104 Avenue, Surrey, B.C., V3T 1V8
Tel: 604-590-7274
E-mail: purchasing@surrey.ca

ADDENDUM No. 1

REQUEST FOR QUOTATION No.:	1220-040-2022-078
TITLE:	HVAC REPLACEMENT, NEWTON WAVE POOL
ADDENDUM ISSUE DATE:	SEPTEMBER 13, 2022
DATE:	PREFER TO RECEIVE SUBMISSION ON OR BEFORE SEPTEMBER 22, 2022

INFORMATION FOR CONTRACTORS

Contractors are advised that Addendum No. 1 to 1220-040-2022-078 is hereby issued by the City. This addendum shall form part of the contract documents and is to be read, interpreted and coordinated with all other parts. The following information is provided to answer questions raised by Contractors for the above-named project, to the extent referenced and shall become a part thereof. No consideration will be allowed for extras due to the Contractors or any sub-contractor not being familiar with this addendum. This Addendum No. 1 contains two (2) pages.

QUESTIONS AND ANSWERS:

- Q1.** Please confirm the total number of Units that are to be replaced.
- A1.** Three Units are to be replaced.
- Q2.** Please confirm how many curbs/sleepers are required with size or will the existing openings be re-used?
- A2.** As seen in specifications; replace existing curbs and all associated roof repairs, new curb adaptors and new sleepers.
- Q3.** Are there any miscellaneous penetrations such as gas and electrical?
- A3.** There was existing gas and electrical penetrations, but if they are sized to the new units properly is up to the potential contractor. The purpose of the site visit was to investigate this, and measure as needed. An additional site visit may be requested if needed.

Q4. Can the City please provide site specific Specifications?

A4. Additional file "HVAC Spec – Newton Wave Pool Details" has been uploaded with this addendum and is added to "Schedule B – Appendix 2 – Supplementary Specification (Project) and Contract Drawings". Any duplicate information in "HVAC Spec – Newton Wave Pool Details" will supersede the information already listed within "Schedule B – Appendix 2 – Supplementary Specification (Project) and Contract Drawings".

Q5. Can the City please provide site drawings?

A5. Additional file "PLN-N Newton Wave Pool_Full Set_2003" has been uploaded with this addendum and is added to "Schedule B – Appendix 2 – Supplementary Specification (Project) and Contract Drawings". Please note that these drawings are provided for reference purposes only. The City will not be held liable or responsible for the accuracy of these provided drawings.

All Addenda will become part of the Contract Documents.

- END OF ADDENDUM -