



PROCUREMENT SERVICES

CITY OF SURREY, SURREY CITY HALL
13450 – 104 Avenue, Surrey, B.C., V3T 1V8
Tel: 604-590-7274
E-mail: purchasing@surrey.ca

ADDENDUM No. 1

REQUEST FOR QUOTATIONS No.: 1220-040-2022-080

TITLE: Sump Pump Installation at Surrey Archives

ADDENDUM ISSUE DATE: October 14, 2022

REVISED DATE: PREFER TO RECEIVE QUOTATIONS ON OR BEFORE **November 3, 2022.**

INFORMATION FOR CONTRACTORS

Contractors are advised that Addendum No.1 to RFQ # 1220-040-2022-080 is hereby issued by the City. This addendum shall form part of the contract documents and is to be read, interpreted and coordinated with all other parts. The following information is provided to answer questions raised by Contractors for the above-named project, to the extent referenced and shall become a part thereof. No consideration will be allowed for extras due to the Contractors or any sub-contractor not being familiar with this addendum. This Addendum No.1 contains three (3) pages in total.

REVISED CLOSING DATE:

The City would prefer to receive Quotations on or before November 3, 2022.

CLARIFICATION

1. **The City will take responsibility for testing and abatement of hazardous materials (asbestos, lead paint, flooring tiles).**


INFORMATION ONLY

1. **Refer to Schedule C – Form of Quotation.**

Delete Schedule C (Form of Quotation) in its entirety and substitute with the attached Schedule C (Form of Quotation).


QUESTIONS AND ANSWERS:

Q1. In the drawing package there are two elevation drawings for the sump. One is concrete with an H2O (vehicle loading) hatch and other is for a fiberglass basin. Can you confirm which type of basin will be used?



3 STORM PUMP SUMP DETAIL
SCALE: N.T.S.

and the other is for a fibreglass basin:



A1. The construction of the pump basin shall be of concrete construction, concrete with an H20 (vehicle loading) hatch.

All Addenda will become part of the Contract Documents.

- END OF ADDENDUM -