



## PROCUREMENT SERVICES

CITY OF SURREY, SURREY CITY HALL  
13450 – 104 Avenue, Surrey, B.C., V3T 1V8  
Tel: 604-590-7274  
E-mail: [purchasing@surrey.ca](mailto:purchasing@surrey.ca)

### ADDENDUM No. 3

---

REQUEST FOR QUOTATIONS No.: 1220-040-2022-080

TITLE: Sump Pump Installation at Surrey Archives

ADDENDUM ISSUE DATE: October 28, 2022

DATE: PREFER TO RECEIVE QUOTATIONS ON OR BEFORE November 3, 2022.

---

### INFORMATION FOR CONTRACTORS

Contractors are advised that Addendum No. 3 to RFQ # 1220-040-2022-080 is hereby issued by the City. This addendum shall form part of the contract documents and is to be read, interpreted and coordinated with all other parts. The following information is provided to answer questions raised by Contractors for the above-named project, to the extent referenced and shall become a part thereof. No consideration will be allowed for extras due to the Contractors or any sub-contractor not being familiar with this addendum. This Addendum No.3 contains seven (7) pages in total including attachment.

### QUESTIONS AND ANSWERS:

- Q1. Can we use the alternative Liberty pumps XLE51M-3, with compatible panel and rail-guide as attached?
- A1. Yes. Referring to the proposed provided attachment, the alternative pump is allowed to be used. The alternative pump performance data shall be the same as the specified sump pump performance data including the pump head, flow rate, and the motor size.**
- Q2. Most H20 rated gastight Hatch covers are designed to handle H20 loading only in locations where they are subjected to Occasional traffic. Is this sump subjected to occasional traffic only?
- A2. Correct. H20 loading is sufficient for this project.**

---

All Addenda will become part of the Contract Documents.

---

- END OF ADDENDUM -