



**PROCUREMENT SERVICES**

**CITY OF SURREY, SURREY CITY HALL  
13450 – 104 Avenue, Surrey, B.C., V3T 1V8  
Tel: 604-590-7274  
E-mail: [purchasing@surrey.ca](mailto:purchasing@surrey.ca)**

**ADDENDUM No. 5**

---

**INVITATION TO TENDER No.:** 1220-020-2024-004

**TITLE:** Modular Daycare Addition at Don Christian Rec Centre

**ADDENDUM ISSUE DATE:** May 14, 2024

**CLOSING DATE AND TIME:** ON OR BEFORE THE FOLLOWING DATE AND TIME (THE “CLOSING TIME”):

**TIME:** 11:00 a.m. (LOCAL TIME)

**May 17, 2024**

---

**INFORMATION FOR TENDERERS**

Tenderers are advised that Addendum No. 5 to 1220-020-2024-004 is hereby issued by the City. This addendum shall form part of the contract documents and is to be read, interpreted and coordinated with all other parts. The following information is provided to answer questions raised by Tenderers for the above-named project, to the extent referenced and shall become a part thereof. No consideration will be allowed for extras due to the Tenderers or any sub-contractor not being familiar with this addendum. This Addendum No. 5 contains two (2) pages.

**CLARIFIED CLOSING DATE AND TIME:**

To correct a previous inconsistency in the closing time as stated in Addendum 2, the “REVISED CLOSING TIME” in Addendum 2 is to be replaced with the section below.

“Delete section 1.3 in its entirety and substitute with section 1.3 below:

## 1.0 Closing Time and Address For Tender Delivery

- .3 Confirmation of receipt of email will be issued. *Tenders* that cannot be opened or viewed may be rejected. A *Tenderer* bears all risk that the *Owner's* receiving computer equipment functions properly so that the *Tender* is received:

**on or before the following date and time**

**Tender Closing Time: 11:00 a.m., local time**

**Tender Closing Date: May 17, 2024**

**(the "Closing Time")."**

### **QUESTIONS AND ANSWERS:**

**Q1.** The geotechnical report states foundations must be at least 450mm below interior concrete slab for an unheated crawlspace. The drawings show the crawlspace unheated, but clearly show less than 450mm below interior slab. Please confirm which is correct.

**A1. As per soils report, for an unheated crawlspace, all foundations including interior ones must be at least 450mm below interior concrete slab (50 seal slab).**

---

All Addenda will become part of the Contract Documents.

---

**- END OF ADDENDUM -**