



## PROCUREMENT SERVICES

CITY OF SURREY, SURREY CITY HALL  
13450 – 104 Avenue, Surrey, B.C., V3T 1V8  
Tel: 604-590-7274  
E-mail: [purchasing@surrey.ca](mailto:purchasing@surrey.ca)

### ADDENDUM No. 3

---

REQUEST FOR QUOTATIONS No.: 1220-040-2024-034

TITLE: SURREY SPORT AND LEISURE COMPLEX - CHILD  
MINDING PLAY SPACE AND MULTI-PURPOSE  
ROOM RENOVATION

ADDENDUM ISSUE DATE: OCTOBER 09, 2024

REVISED DATE: PREFER TO RECEIVE SUBMISSION ON OR BEFORE  
OCTOBER 10, 2024.

---

### INFORMATION FOR APPLICANTS

Applicants are advised that Addendum No. 3 to 1220-040-2024-034 is hereby issued by the City. This addendum shall form part of the contract documents and is to be read, interpreted and coordinated with all other parts. The following information is provided to answer questions raised by Applicants for the above-named project, to the extent referenced and shall become a part thereof. No consideration will be allowed for extras due to the Applicants or any sub-contractor not being familiar with this addendum. This Addendum No. 3 contains two (2) pages.

### QUESTIONS AND ANSWERS:

**Q1.** Please confirm the Base Building Distribution Equipment Manufacturer (OEM) so that we can find the right breakers to add or to replace when necessary.

**A1. Siemens.**

**Q2.** Please confirm that there is no Division 27 Data/Communications, CCTV, and other Division 28 Scope of Work, except Access Control.

**A2. Division 27 Data/Communications, CCTV, and other Division 28 are not in Scope of Work.**

**Q3.** Please advise the wattage required for type BP (mini-inverter). The specification reads 300W-1440W?

**A3. 300W is required for BP-1.**

---

---

All Addenda will become part of the Contract Documents.

---

---

- END OF ADDENDUM -