



PROCUREMENT SERVICES

CITY OF SURREY, SURREY CITY HALL
13450 – 104 Avenue, Surrey, B.C., V3T 1V8
Tel: 604-590-7274
E-mail: purchasing@surrey.ca

ADDENDUM No. 2

REQUEST FOR QUOTATIONS No.: 1220-040-2024-042

TITLE: SUPPLY AND INSTALLATION, UPGRADE
AND EXPAND EV CHARGING STATIONS

ADDENDUM ISSUE DATE: AUGUST 21, 2024

DATE: AUGUST 29, 2024

INFORMATION FOR CONTRACTORS

Contractors are advised that Addendum No. 2 to 1220-040-2024-042 is hereby issued by the City. This addendum shall form part of the contract documents and is to be read, interpreted and coordinated with all other parts. The following information is provided to answer questions raised by Contractors for the above-named project, to the extent referenced and shall become a part thereof. No consideration will be allowed for extras due to the Contractors or any sub-contractor not being familiar with this addendum. This Addendum No. 2 contains one (1) page.

QUESTIONS AND ANSWERS:

Q1: Could you please provide clarification on the metering requirements.

A1: A separate Quad Logic Meter must be installed, commissioned and tested to monitor the three new supplies as indicated on the SLD. The meter shall match the existing installed Quad Logic meter on site and shall be installed adjacent to the existing two meters in the main electrical room, on the east wall.

Q2: Panel Labelling - Panel P2G4 is actually named P1G4 on Panel and Disconnect. Are they renaming is P2G4 or does it remain P1G4 since its located on P1?

A2: Panel should be labelled as P1G4 as it is housed on the P1 level.

All Addenda will become part of the Contract Documents.

- END OF ADDENDUM -