



## PROCUREMENT SERVICES

CITY OF SURREY, SURREY CITY HALL  
13450 – 104 Avenue, Surrey, B.C., V3T 1V8  
Tel: 604-590-7274  
E-mail: [purchasing@surrey.ca](mailto:purchasing@surrey.ca)

### ADDENDUM No. 2

---

REQUEST FOR PROPOSAL No.:	1220-030-2024-042
TITLE:	WATER LEAK DETECTION, ACOUSTIC, PILOT PROJECT
ADDENDUM ISSUE DATE:	OCTOBER 25, 2024
CLOSING DATE AND TIME:	ON OR BEFORE THE FOLLOWING DATE AND TIME (THE “CLOSING TIME”):
	TIME: 3:00 P.M. (LOCAL TIME)
	DATE: NOVEMBER 6, 2024

---

### INFORMATION FOR PROPONENTS

Proponents are advised that Addendum No. 2 to 1220-030-2024-042 is hereby issued by the City. This addendum shall form part of the contract documents and is to be read, interpreted and coordinated with all other parts. The following information is provided to answer questions raised by Proponents for the above-named project, to the extent referenced and shall become a part thereof. No consideration will be allowed for extras due to the Proponents or any sub-contractor not being familiar with this addendum. This Addendum No. 2 contains two (2) pages.

#### REVISED CLOSING TIME:

Delete Section 2.1 in its entirety and substitute with Section 2.1 below:

#### **“2.1 Closing Time and Address for Proposal Delivery**

The Proponent should submit the Proposal **electronically** in a single pdf file which must be delivered by email at: [purchasing@surrey.ca](mailto:purchasing@surrey.ca)

**on or before the following date and time**

**Time: 3:00 p.m., local time**

**Date: November 6, 2024**

**(the “Closing Time”).**

Confirmation of receipt of email will be issued. Proposals that cannot be opened or viewed may be rejected. A Proponent bears all risk that the City’s receiving computer equipment functions properly so that the Proposal is received by the Closing Time.

**Note:** The maximum file size the City can receive is 10Mb. If sending large email attachments, Proponents should phone [604-590-7274] to confirm receipt.”

**QUESTIONS AND ANSWERS:**

**Q1.** Would it be okay if we have multiple sub-contractors?

**A1. Yes, please list sub-contractors within the response form.**

**Q2.** What is the normal operating pressures on the pipelines?

**A2. Operating pressure is between 60psi and 120psi.**

**Q3.** What is the inlet availability and inlet size?

**A3. There is distribution pipes ranging from 100mm to 300mm and standard hydrant leads are typically 150mm. If the equipment has been used in other municipalities in the lower mainland then it should be comparable to Surrey.**

**Q4.** Is there power availability?

**A4. The contractor would need to reach out to BC Hydro to confirm if it is available. Alternatively, battery powered equipment could be used.**

**Q5.** Could you please provide watermain data?

**A5. Please see: <https://www.surrey.ca/services-payments/online-services/open-data>**

---

All Addenda will become part of the Contract Documents.

---

**- END OF ADDENDUM -**