



PROCUREMENT SERVICES

**CITY OF SURREY, SURREY CITY HALL
13450 – 104 Avenue, Surrey, B.C., V3T 1V8
Tel: 604-590-7274
E-mail: purchasing@surrey.ca**

ADDENDUM No. 1

REQUEST FOR QUOTATION No.: 1220-040-2024-066
TITLE: SURREY PUBLIC WHARF REPAIRS
ADDENDUM ISSUE DATE: September 16, 2024
DATE: PREFER TO RECEIVE SUBMISSION ON OR BEFORE SEPTEMBER 26, 2024.

INFORMATION FOR CONTRACTORS

Contractors are advised that Addendum No. 1 to 1220-040-2024-066 is hereby issued by the City. This addendum shall form part of the contract documents and is to be read, interpreted and coordinated with all other parts. The following information is provided to answer questions raised by Contractors for the above-named project, to the extent referenced and shall become a part thereof. No consideration will be allowed for extras due to the Contractors or any sub-contractor not being familiar with this addendum. This Addendum No. 1 contains one (1) page.

QUESTIONS AND ANSWERS:

Q1. Referencing to # 2.3, Technical Specifications, Drawing Sheet S001:

The technical specifications require that the new timber be treated with ACZA concentrate treatment for Use Category 5A. However, a supplier mentions that UC 5A is for materials that are submerged in salt water and the supplier recommends all the material should be treated at most UC 4.1. Please confirm if UC 5A is a requirement.

A1. UC 4.1 is acceptable as the minimum standard.

All Addenda will become part of the Contract Documents.

- END OF ADDENDUM -