



PROCUREMENT SERVICES

**CITY OF SURREY, SURREY CITY HALL
13450 – 104 Avenue, Surrey, B.C., V3T 1V8
Tel: 604-590-7274
E-mail: purchasing@surrey.ca**

ADDENDUM No. 2

REQUEST FOR QUOTATION No.: 1220-040-2024-066
TITLE: SURREY PUBLIC WHARF REPAIRS
ADDENDUM ISSUE DATE: September 20, 2024
DATE: PREFER TO RECEIVE SUBMISSION ON OR BEFORE SEPTEMBER 26, 2024.

INFORMATION FOR CONTRACTORS

Contractors are advised that Addendum No. 2 to 1220-040-2024-066 is hereby issued by the City. This addendum shall form part of the contract documents and is to be read, interpreted and coordinated with all other parts. The following information is provided to answer questions raised by Contractors for the above-named project, to the extent referenced and shall become a part thereof. No consideration will be allowed for extras due to the Contractors or any sub-contractor not being familiar with this addendum. This Addendum No. 1 contains one (1) page.

QUESTIONS AND ANSWERS:

Q1. Would pressure-treated pine lumber be an acceptable alternative?

A1. No

All Addenda will become part of the Contract Documents.

- END OF ADDENDUM -