



PURCHASING SECTION
13450 – 104 Avenue, Surrey BC V3T 1V8
Tel: 604-590-7274
E-mail: purchasing@surrey.ca

ADDENDUM #3

REQUEST FOR QUOTATIONS (RFQ) NO.: 1220-040-2018-063
TITLE: CONSTRUCTION SERVICES – SURREY
HERITAGE TOWN HALL EXTRACTION
ADDENDUM ISSUE DATE: July 13, 2018
REVISED CLOSING DATE: prefer to receive Quotations on or before:
July 19, 2018

INFORMATION FOR CONTRACTORS

This Addendum is issued to provide additional information to the RFQ for the above named project, to the extent referenced and shall become a part thereof. No consideration will be allowed for extras due to the Contractor not being familiar with this Addendum. This Addendum No. 3 contains one (1) page in total.

CLARIFICATIONS:

- 1) E200 – Electrical Specification

SECTION 28 – LIGHTING LUMINAIRES AND LIGHTING CONTROLS

Clarification: New lighting system is not required. Existing lighting and control system shall remain as is. Remove only lighting in demolition areas and re-route any lighting circuits servicing non-demolition areas that go through demolition areas.

- 2) Corner Bracing Details DE-A3-00 Detail 5A does not apply to this Contract, only the future building moving contract.
- 3) Corner Bracing Plan Detail DE-A3-00 Detail 5B does not apply to this Contract, only the future building moving contract.
- 4) Window Bracing Detail, 5/S601 does not apply to this Contract, only the future building moving contract.

END OF ADDENDUM #3

All Addenda will become part of the RFQ Documents.
