



PROCUREMENT SERVICES

City of Surrey, Surrey City Hall
13450 – 104 Avenue, Surrey, B.C., V3T 1V8

Tel: 604-590-7274

E-Mail: purchasing@surrey.ca

ADDENDUM #3

INVITATION TO TENDER NO.: 1220-020-2020-004

TITLE: ORCHARD GROVE PARK MULTI-USE
PATHWAY

ADDENDUM ISSUE DATE: May 19 2020

ON OR BEFORE THE FOLLOWING DATE
AND TIME (THE "CLOSING TIME"):

CLOSING TIME:

TIME: 11:00 A.M. (LOCAL TIME)

DATE: MAY 21, 2020

INFORMATION FOR TENDERERS

This Addendum is issued to provide additional information to the ITT #1220-020-2020-004 for the above-named project, to the extent referenced and shall become part thereof. No consideration will be allowed for extras due to the Tenderer not being familiar with this Addendum. This Addendum No. 3 contains two (2) pages in total.

QUESTIONS AND ANSWERS:

Q1: For sodding for Orchard Grove, who is responsible for watering? There is no mention of watering in the Surrey supplementary specs (Section 32 92 23).

A1: As per MMCD Section 32 92 23 Sodding - Item 3.4 Grass Maintenance – The contractor is responsible for maintaining the sod until issuance of Certificate of Total Performance.

Q2: Please confirm the type of hydrant?

A2: Note that the existing hydrant does not need to be replaced (adjustment only). Hydrant installation shall be in accordance with MMCD Standard Drawing W4. Refer to the City

of Surrey Approved Products List for acceptable hydrant manufacturers when selecting parts required for the adjustment.

Q3: Kindly confirm that the bond presentation in electronic format (electronic copy) is an acceptable format or are we to hand-deliver the original signed/sealed version?

A3: An electronic copy of the bid bond as part of the tender is acceptable, however, the awardee may be asked for an original. Refer to page #2 of the ITT - INVITATION TO TENDERERS for further instructions.

- END OF ADDENDUM -

All Addenda will become part of the ITT Documents.
