

PROCUREMENT SERVICES

CITY OF SURREY, SURREY CITY HALL 13450 – 104 Avenue, Surrey, B.C., V3T 1V8 Tel: 604-590-7274

E-mail: purchasing@surrey.ca

ADDENDUM No. 2

REQUEST FOR TENDER No.: 1220-020-2023-004

TITLE: DISTRICT ENERGY TRANSFER STATIONS AND

ASSOCIATED WORKS

ADDENDUM ISSUE DATE: AUGUST 30, 2023

ON OR BEFORE THE FOLLOWING DATE AND

TIME (THE "CLOSING TIME"):

CLOSING DATE AND TIME:

TIME: 11:00 A.M. (LOCAL TIME)

DATE: SEPTEMBER 7, 2023

INFORMATION FOR TENDERERS

Tenderers are advised that Addendum No. 2 to 1220-020-2023-004 is hereby issued by the City. This addendum shall form part of the contract documents and is to be read, interpreted and coordinated with all other parts. The following information is provided to answer questions raised by Tenderers for the above-named project, to the extent referenced and shall become a part thereof. No consideration will be allowed for extras due to the Tenderers or any sub-contractor not being familiar with this addendum. This Addendum No. 2 contains one (1) page.

CLARIFICATION:

1. In Part G – Drawings:

(a) Delete *Drawing* reference D-1530 as issued for tender in its entirety and substitute with the attached new *Drawing* No. D-1530, Rev. 0.1.

DPS Layout has been added on the City's MFT site. The revision pertains to pipe size from DN150 to DN80.

All Addenda will become part of the Contract Documents.

- END OF ADDENDUM -