



PROCUREMENT SERVICES

CITY OF SURREY, SURREY CITY HALL
13450 – 104 Avenue, Surrey, B.C., V3T 1V8
Tel: 604-590-7274
E-mail: purchasing@surrey.ca

ADDENDUM No. 1

REQUEST FOR QUOTATIONS No.:	1220-040-2023-030
TITLE:	SUPPLY AND DELIVERY OF 300MM WATERMAIN
ADDENDUM ISSUE DATE:	MAY 17, 2023
REVISED DATE:	PREFER TO RECEIVE SUBMISSION ON OR BEFORE MAY 25, 2023

INFORMATION FOR CONTRACTORS

Contractors are advised that Addendum No. 1 to 1220-040-2023-030 is hereby issued by the City. This addendum shall form part of the contract documents and is to be read, interpreted and coordinated with all other parts. The following information is provided to answer questions raised by Contractors for the above-named project, to the extent referenced and shall become a part thereof. No consideration will be allowed for extras due to the Contractors or any sub-contractor not being familiar with this addendum. This Addendum No. 1 contains two (2) pages.

QUESTIONS AND ANSWERS:


Q1. Please confirm configuration on item #4 of Fees and Payments in Schedule B – Form of Quotation: Hub (tyt) x MJ x MJ is not available and not made.

A1. 300mm MJ x 300mm MJ x 150mm Hub. If Hub is not available, 150mm MJ may be quoted.

Q2. Please clarify the required tees noted in item #3 and #4 of Fees and Payments in Schedule B – Form of Quotation: provide sizes and end types for A x B x C per below.

Reading/describing a tee:

- A x B x C
- A to B is the through line.
- C is the branch.
- This is to be consistent for describing both the sizes and end types.



- A2. Item number 3: 300mm MJ x 300mm MJ x 150mm FL**
Item number 4: 300mm MJ x 300mm MJ x 150mm Hub (If Hub not available, can be MJ)

All Addenda will become part of the Contract Documents.

- END OF ADDENDUM -