



PROCUREMENT SERVICES SECTION
Surrey City Hall, 13450 – 104 Avenue, Surrey, B.C., V3T 1V8
Tel: 604-590-7274
E-Mail: purchasing@surrey.ca

ADDENDUM #4

REQUEST FOR QUOTATIONS (RFQ) No. : 1220-040-2023-039

**TITLE: RELINE AND POINT REPAIR PROGRAM –
SANITARY SEWER MAINS AND
LATERALS**

ADDENDUM ISSUE DATE: July 24th, 2023

**CLOSING DATE: Prefer to receive Quotations on or before
July 25th, 2023**

INFORMATION FOR CONTRACTORS

This Addendum is issued to provide additional information to the RFQ for the above-named project, to the extent referenced and shall become thereof. No consideration will be allowed for extras due to the Contractor not being familiar with this Addendum. This Addendum No. 4 contains one (1) page in total.

QUESTIONS AND ANSWERS:

Q.1. I was hoping for your definition on your use of the word “T-Liner”. Referring to just a seal of the lateral connection at the mainline sewer. At the junction of lateral to main. (most time referred to as a “tophat”) or a small sectional spot repair in the mainline with the full length lateral?

A.1. T-liner would be defined as a sectional spot repair in the mainline as well as the full length lateral, where the overlap is sealed.

If proposing a “top hat” style liner, Contractors are to detail this as a requested departure in section 4 of Schedule C.

– END OF ADDENDUM –

All Addenda will become part of the RFQ Documents.
