



Engineering
Electrical & Electronic

Permit to Practice: #1001261

TENDER ADDENDUM #1

PROJECT NO: 22-517
PROJECT NAME: CoS SSIC Rink Lighting Upgrade

DATE: April 11, 2023
ISSUED BY: Mo Khan

TO: Attn: Carlos Aller
City of Surrey
6651 148th Street
Surrey, BC V3S 3C7

The following Addendum shall form part of the referenced tender document for the stated project above, and is to be read, interpreted, and coordinated with all other items. As such, all costs for work performed herein, shall be included within the tender. Thus, the following revisions supersede any information contained within the project's original drawings and specifications. Except for items outlined below, all other terms and conditions shall remain the same as in the original tender documents and if applicable, any previously issued addenda.

1. REFERENCED DRAWING E000

1. Adjust "Specific Project Requirements" #7 to include the following. The contractor will include a 3/4" plyboard to protect the ice floor, in the vicinity of area of work.
2. Adjust "Summary of Scope of Works" #1 to include the following. All lamps from demolished fixtures to be retained and handed over to client.
3. Provide an additional wireless light switch (4 button), complete with anti-tamper enclosure at Zamboni corridor. Provide a 15A 1P circuit from Panel EMA located in the main electrical room, in EMT conduit and #12AWG wiring. Allow for programming of the buttons for on/off, 50% , 75% and 100%

END OF ELECTRICAL ADDENDUM NO. 1